



Jim Doyle, Governor
Mary P. Burke, Secretary

March 13, 2007

WATER SAVER FAUCET COMPANY
MIKE STRAUGHN
701 W ERIE ST
CHICAGO IL 60610

Re: Description: VACUUM BREAKER, LABORATORY FAUCET - ASSE 1035
Manufacturer: WATER SAVER FAUCET COMPANY
Product Name: VACUUM BREAKER
Model Number(s): L7110
Product File No: 20060524

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm Table 82.41-2 and 84.11 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of March 2012.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This product may only be installed for the following conditions:
 1. On a cold water laboratory faucet,
 2. A cold water line,
 3. The pressure at the inlet to this product may not exceed 80 p.s.i., and
 4. Not be employed in backpressure situations of more than 6 feet of water column.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov